

1. THE INSTALLATION OF THE RECYCLED WATER SYSTEM SHALL BE ACCOMPLISHED UNDER THE APPROVAL, INSPECTION, AND TO THE SATISFACTION OF THE YUCAIPA VALLEY WATER DISTRICT (YVWD).
2. CONTRACTOR SHALL SCHEDULE A PRE-CONSTRUCTION MEETING WITH YVWD AT (909)797-5117 TWO (2) WORKING DAYS IN ADVANCE OF STARTING WORK. CONSTRUCTION SHALL BEGIN NO LATER THEN FIVE (5) DAYS AFTER THE PRE-CONSTRUCTION MEETING. YVWD SHALL BE NOTIFIED OF EACH WORKDAY THEREAFTER UNTIL COMPLETION OF THE PROJECT.
3. THE PROPERTY OWNER SHALL BE RESPONSIBLE FOR PROVIDING ACCESS TO AND COOPERATION WITH THE DISTRICT INSPECTOR TO PERFORM ALL INSPECTIONS AND TESTING.
4. CONNECTIONS TO THE EXISTING RECYCLED WATER FACILITIES SHALL BE DONE BY A LICENSED CONTRACTOR PER THE YVWD RECYCLED WATER ON-SITE DESIGN AND CONSTRUCTION STANDARDS.
5. THERE SHALL NEVER BE DIRECT CONNECTIONS BETWEEN THE POTABLE AND RECYCLED WATER SYSTEMS.
6. RECYCLED WATER SHALL NOT BE USED FOR ANY PURPOSE OTHER THAN LANDSCAPE IRRIGATION AND APPROVED USES SUCH AS INDUSTRIAL USE OR IMPOUNDMENTS.
7. HOSE BIBS ARE PROHIBITED ON RECYCLED WATER SYSTEMS.
8. WATER USED IN HOSE BIBS SHALL BE POTABLE WATER AND ALL HOSE BIBS SHALL BE AFFIXED TO THE BUILDING.
9. THE POTABLE WATER SYSTEM SHALL BE PROTECTED BY AN APPROVED BACKFLOW PREVENTION DEVICE. THE RECYCLED WATER SERVICE WILL NORMALLY NOT REQUIRE BACKFLOW PROTECTION (AT YVWD DISCRETION).
10. A MINIMUM OF TEN (10) FEET HORIZONTAL SEPARATION MUST BE MAINTAINED AT ALL TIMES BETWEEN THE CONSTANT PRESSURE POTABLE AND RECYCLED WATER LINES. A MINIMUM OF ONE (1) FOOT VERTICAL SEPARATION MUST BE MAINTAINED AT ALL TIMES BETWEEN THE POTABLE AND RECYCLED WATER LINES WITH THE RECYCLED WATERLINE BELOW THE POTABLE.
11. ALL CROSSINGS BETWEEN POTABLE AND RECYCLED WATER LINES SHALL BE AS NEAR TO PERPENDICULAR AS POSSIBLE AND THE RECYCLED WATER LINES SHALL BE SLEEVED A MINIMUM OF FIVE (5) FEET ON BOTH SIDES OF THE POTABLE WATER LINE.
12. HE USE OF CONTINUOUS LETTERING ON 3-INCH MINIMUM WIDTH BLUE TAPE WITH 1-INCH BLACK OR WHITE CONTRASTING LETTERING BEARING THE CONTINUOUS WORDING "POTABLE WATER" PERMANENTLY AFFIXED AT 10-FOOT INTERVALS ATOP ALL HORIZONTAL PIPING, LATERALS, AND MAINS. REFER TO T. CHRISTY'S OR APPROVED EQUAL. IDENTIFICATION TAPE IS NOT NECESSARY FOR EXTRUDED BLUE-COLORED PVC WITH CONTINUOUS WORDING "POTABLE WATER" PRINTED IN CONTRASTING LETTERING ON OPPOSITE SIDES OF THE PIPE.
13. THE USE OF CONTINUOUS LETTERING ON 3-INCH MINIMUM WIDTH PURPLE TAPE WITH 1-INCH BLACK OR WHITE CONTRASTING LETTERING BEARING THE CONTINUOUS WORDING "CAUTION- RECYCLED WATER" PERMANENTLY AFFIXED AT 10-FOOT INTERVALS ATOP ALL HORIZONTAL PIPING, LATERALS, AND MAINS. REFER TO T. CHRISTY'S OR APPROVED EQUAL. IDENTIFICATION TAPE IS NOT NECESSARY FOR EXTRUDED PURPLE-COLORED PVC WITH CONTINUOUS WORDING "CAUTION - RECYCLED WATER" PRINTED IN CONTRASTING LETTERING ON OPPOSITE SIDES OF THE PIPE.

(CONTINUED ON SHEET 2 OF 2)

RECYCLED WATER NOTES FOR NON-RESIDENTIAL SITES

2016



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on March 16, 2016 as
Resolution No. 2016-13

R-3

Sheet 1 of 2

(CONTINUED FROM SHEET 1 OF 2)

14. ALL NEW BURIED RECYCLED WATER LINES (PRESSURE/NON-PRESSURE) MUST BE PURPLE-COLORED SCHEDULE 40 (MINIMUM) PVC PIPE WITH CONTINUOUS WORDING "CAUTION - RECYCLED WATER" PRINTED ON OPPOSITE SIDES OF THE PIPE.
15. RECYCLED WATER ISOLATION AND CONTROL VALVE BOXES SHALL BE WEATHERPROOF PURPLE PLASTIC AND MARKED "RECYCLED WATER". *NOTE-ALL CONTROL VALVES SHALL BE BURIED BELOW GRADE AUTOMATIC CONTROL VALVES OPERATED BY A PROGRAMMABLE CONTROLLER. ABOVE GROUND ANTI-SIPHON CONTROL VALVES ARE NOT ALLOWED.
16. ALL RECYCLED WATER IRRIGATION SYSTEM CONTROL VALVES, ISOLATION VALVES, QUICK COUPLERS, REGULATORS, AND APPURTENANCES SHALL BE TAGGED. IDENTIFICATION SHALL BE WEATHERPROOF PURPLE PLASTIC, 3-INCHES BY 4-INCHES AND IMPRINTED WITH "WARNING RECYCLED WATER - DO NOT DRINK" IN BOTH ENGLISH AND SPANISH. REFER TO T. CHRISTY'S OR APPROVED EQUAL.
17. ALL AREAS WHERE RECYCLED WATER IS USED SHALL BE POSTED WITH APPROVED SIGNAGE. EACH SIGN SHALL STATE "RECYCLED WATER - DO NOT DRINK" AND DISPLAY THE INTERNATIONAL "DO NOT DRINK" SYMBOL.
18. BEFORE ACTIVATION OF THE POTABLE WATER SERVICE THE BACKFLOW DEVICE SHALL BE TESTED AND APPROVED BY A LICENSED BACKFLOW TESTER. ARRANGEMENTS WITH YVD MUST BE MADE AT LEAST TWO (2) WORKING DAYS IN ADVANCE TO TURN ON THE POTABLE SERVICE TO ALLOW TESTING OF THE DEVICE. POTABLE WATER SERVICE WILL NOT BE ACTIVATED UNTIL THE BACKFLOW DEVICE PASSES INSPECTION.
19. BEFORE ACTIVATION OF THE RECYCLED WATER SERVICE, A CROSS CONNECTION TEST AND FINAL INSPECTION AND APPROVAL OF THE IRRIGATION SYSTEM SHALL BE PERFORMED. THE PROPERTY OWNER OR CONTRACTOR SHALL ARRANGE WITH THE DISTRICT FOR AN IRRIGATION COVERAGE TEST AND MAKE ANY MODIFICATIONS OR ADJUSTMENTS DEEMED REQUIRED BEFORE FINAL APPROVAL.
20. ALL SPRAY HEADS SHALL BE ADJUSTED TO ELIMINATE OVERSPRAY AND RUNOFF ONTO ADJACENT HARDSCAPES, DRINKING FOUNTAINS OR WATER FEATURES, AND OUTDOOR FURNITURE SUCH AS PICNIC TABLES, ETC.
21. RECYCLED WATER IRRIGATION SYSTEMS SHALL ONLY BE OPERATED BETWEEN THE HOURS OF 9:00 PM AND 6:00 AM.
22. FAILURE TO COMPLY WITH ANY OF THE YUCAIPA VALLEY WATER DISTRICT STANDARDS MAY RESULT IN TERMINATION OF RECYCLED WATER AND/OR POTABLE WATER SERVICE.

RECYCLED WATER NOTES FOR NON-RESIDENTIAL SITES

2016



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on March 16, 2016 as
Resolution No. 2016-13

R-3

Sheet 2 of 2