



NOTE:

1. POTABLE WATER METER SHALL BE LOCATED A MINIMUM OF 10- FEET AWAY FROM THE RECYCLED WATER SERVICE AND SEWER LATERAL, AND 3- FEET AWAY FROM THE E.C./B.C. OF THE DRIVEWAY APPROACH. IF THESE SEPARATIONS ARE NOT POSSIBLE, THE POTABLE WATER METER MAY BE LOCATED WITHIN THE DRIVEWAY BEHIND THE APPROACH BY SPECIAL PERMISSION ONLY.

RESIDENTIAL DUAL PLUMBED SERVICE SCHEMATIC

2016



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on March 16, 2016 as Resolution No. 2016-13

R-20

Sheet 1 of 1