



NOTES:

1. THIS EXAMPLE OF AN IRRIGATION PLAN SUBMITTAL REPRESENTS THE MINIMUM PLAN SUBMITTAL REQUIREMENT.
2. IRRIGATION LEGEND SHALL BE INCLUDED ON THE PLAN. SEE YWD STD. DWG. R-1 FOR EXAMPLE OF IRRIGATION PLAN LEGEND.
3. DRINKING WATER METER SHALL BE LOCATED A MINIMUM OF 10- FEET AWAY FROM THE RECYCLED WATER SERVICE AND SEWER LATERAL, AND 3- FEET AWAY FROM THE E.C./B.C. OF THE DRIVEWAY APPROACH. IF THESE SEPARATIONS ARE NOT POSSIBLE, THE DRINKING WATER METER MAY BE LOCATED WITHIN THE DRIVEWAY BEHIND THE APPROACH BY SPECIAL PERMISSION ONLY.

RESIDENTIAL LOT IRRIGATION LAYOUT PLAN SUBMITTAL EXAMPLE

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

R-21

Sheet 1 of 1