



| LIST OF MATERIALS | |
|-------------------|---|
| ITEM NO. | DESCRIPTION |
| 1 | SCH 80 MAINLINE |
| 2 | PRESSURE REDUCING REGULATOR AS REQUIRED |
| 3 | LINE SIZE X LINE SIZE X 3/4" SCH 80 TEE (SOC X SOC X THD) |
| 4 | 3/4" SCH 80 NIPPLE |
| 5 | 3/4" SCH 80 ELBOW (THD X THD) |
| 6 | 1/4" BRONZE BALL VALVE (FIP X FIP) |
| 7 | 3/8" DIA. PEA GRAVEL SUMP (MIN. 1 CUBIC FT.) |
| 8 | PURPLE COLOR JUMBO VALVE BOX AND LID |

NON-RESIDENTIAL RECYCLED WATER CROSS CONNECTION CONTROL TEST STATION DETAIL

2016



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on March 16, 2016 as
Resolution No. 2016-13

R-23