



LIST OF MATERIALS	
ITEM NO.	DESCRIPTION
1	SCH 80 MAINLINE
2	PRESSURE REDUCING REGULATOR AS REQUIRED
3	LINE SIZE X LINE SIZE X 3/4" SCH 80 TEE (SOC X SOC X THD)
4	3/4" SCH 80 NIPPLE
5	3/4" SCH 80 ELBOW (THD X THD)
6	3/4" QUICK COUPLER
7	3/8" DIA. PEA GRAVEL SUMP (MIN. 1 CUBIC FT.)
8	PURPLE COLOR JUMBO VALVE BOX AND LID

## RECYCLED WATER CROSS CONNECTION CONTROL TEST STATION DETAIL

2017



Yucaipa Valley Water District

Approved by the Yucaipa  
Valley Water District Board of  
Directors on October 17, 2017  
as Resolution No. 2017-24

R-23

Sheet 1 of 1