



NOTES:

1. CONTROL WIRING (AWG. UF #14.). SECURE TO TERMINAL STRIP PROVIDED IN ENCLOSURE.
2. COMMON WIRE TO BE WHITE AND CONTROL WIRE TO BE RED. BUNDLE AND TAPE WIRING AT INTERVALS OF 5'-0" O.C.
3. INSTALL ON/OFF SWITCH FOR ELECTRICAL SUPPLY INSIDE OF CONTROLLER.

4. INSTALL CONTROLLER MARKING STICKER: "ATTENTION – CONTROLLER UNIT FOR RECYCLED WATER" ATTACH STICKER INSIDE CONTROLLER CABINET DOOR.

ONSITE IRRIGATION AUTOMATIC CONTROLLER – WALL MOUNT

2016



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on March 16, 2016 as Resolution No. 2016-13

R-24