



NOTES:

1. PLACE TWO HALF MOON SHAPED PLYWOOD COVERS (5/8" THICK MINIMUM) IN BOTTOM OF MANHOLE AFTER SHAFTS HAVE BEEN SET TO KEEP DEBRIS FROM ENTERING SEWER.
2. FOR DROP MANHOLE DETAIL SEE YWD STD. DWG. S-10. (SPECIAL ACCEPTANCE BY DISTRICT ENGINEER ONLY).
3. FOR MANHOLES LOCATED OUTSIDE PAVED AREAS THE FRAME AND COVER SHOULD BE SET A MINIMUM OF 0.1 FT. ABOVE FINISH GRADE IN SHOULDER AREAS, UNPAVED ROADS OR LANDSCAPED AREAS, AND 18" IN UNFINISHED AREAS.
4. ALL INLETS AND OUTLETS SHALL BE SUPPORTED WITH CONCRETE SUPPORTS PRIOR TO POURING MANHOLE BASE.
5. 1/2" OF CEMENT MORTAR TO BE APPLIED BETWEEN ALL GRADE RING JOINTS FROM TOP OF CONE TO MANHOLE FRAME. BETWEEN TOP GRADE RING AND FRAME, UP TO 3" MAX. OF MORTAR MAY BE USED FOR STREET SLOPE ADJUSTMENT. SEE STD. DWG. S-5.

MANHOLE DETAIL

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

S-3