



NOTE:

1. CLEANOUT PIPE TO BE SAME SIZE AND KIND OF MATERIAL AS MAIN.

TERMINAL OR MAINLINE CLEANOUT DETAIL (SPECIAL ACCEPTANCE ONLY)

2016



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on March 16, 2016 as
Resolution No. 2016-13

S-12