



NOTES:

1. 3/4" CRUSHED ROCK MATERIAL SHALL BE USED FOR PIPE ZONE BACK FILL. REMAINING BACK FILL WILL BE IN ACCORDANCE WITH DISTRICT REQUIREMENTS.
2. WHEN DEPTH REACHES 10'-0", ALL PIPE ZONE BEDDING SHALL BE 3/4" CRUSHED ROCK WITH A MINIMUM DEPTH OF 6" BELOW PIPE UNLESS OTHERWISE NOTED ON PLANS.
3. OUTSIDE OF STREET RIGHT OF WAY, COMPACTION SHALL BE 90%.
4. ADDITIONAL ARTERIAL STREET BACKFILL MAY BE REQUIRED BY APPROPRIATE CITY JURISDICTION.
4. SEE SHEET 2 OF 2 FOR PIPE VS. TRENCH SIZES.

TRENCH REPAIR DETAIL

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

S-17

Sheet 1 of 2

TRENCH REPAIR—PIPE SIZE VS TRENCH SIZE		
PIPE SIZE—INCHES (INSIDE DIAMETER)	TRENCH WIDTH—INCHES	
	MINIMUM	MAXIMUM
4	20	28
6	22	32
8	24	32
10	26	36
12	30	36
14	32	42
16	34	42

TRENCH REPAIR DETAIL

2017



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on October 17, 2017
as Resolution No. 2017-24

S-17

Sheet 2 of 2