



FOR EACH LENGTH OF DUCTILE IRON PIPE, CASING SPACERS SHALL BE LOCATED 6'-0" APART AND 3'-0" FROM EACH END OF PIPE. FOR VCP, SPACERS SHALL LOCATED 1' FROM EACH END OF PIPE.

STEEL CASING SCHEDULE

V.C.P. SIZE	MINIMUM CASING SIZE	MIN. WALL THICK.
6"	16" I.D.	1/4"
8"	18" I.D.	1/4"
10"	21" I.D.	5/16"
12"	24" I.D.	5/16"

NOTES:

1. THE ANNULAR SPACE BETWEEN THE CASING AND THE CARRIER PIPE SHALL BE FILLED WITH AIR BLOWN SAND.
2. UNLESS OTHERWISE NOTED, CASING SHALL BE INSTALLED BY THE BORE, JACK AND/OR TUNNEL METHOD. IF OPEN-CUT INSTALLATION OF CASING IS ALLOWED, BACKFILL SHALL BE IN ACCORDANCE WITH YVWD STD. DWG S-17.
3. SIZE AND THICKNESS OF CASING SHALL BE AS SHOWN IN SCHEDULE.
4. ALL STEEL CASING PIPE FIELD JOINTS SHALL BE WELDED FULL-CIRCUMFERENCE.
5. PSI CASING SPACERS SHALL BE PROVIDED PER DETAIL ABOVE.
6. CARRIER PIPE SHALL BE AIR PRESSURE TESTED PRIOR TO FILLING CASING AND AGAIN WITH ENTIRE ENTIER PIPLINE
7. UPSTREAM AND DOWNSTREAM ELEVATIONS OF CARRIER PIPE TO BE VERIFIED PRIOR TO FILLING.
8. EACH END OF CASING SHALL BE SEALED WITH CONCRETE MORTAR.

STEEL CASING PIPE

2016



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on March 16, 2016 as Resolution No. 2016-13

S-20

Sheet 1 of 1