



**STOPPER DETAIL**

**NOTES:**

1. LATERAL SIZE TO BE DETERMINED ON THE BASIS OF TOTAL NUMBER OF FIXTURE UNITS DRAINED, BUT IN NO CASE SHALL THE LATERAL DIAMETER BE LESS THAN FOUR INCHES FOR SINGLE OR MULTIPLE FAMILY RESIDENTIAL AND SIX INCHES FOR COMMERCIAL OR INDUSTRIAL. RISERS SHALL BE THE SAME SIZE AS THE LATERAL.
2. LATERAL TO BE INSTALLED TO PROPERTY LINE. ALL LATERALS ARE TO BE CONSTRUCTED OF EXTRA STRENGTH VITRIFIED CLAY PIPE. MUST BE INSTALLED WITH A MINIMUM HORIZONTAL OFFSET OF 36" FROM ALL OTHER UTILITIES.
3. PLACE 3/4" CRUSHED ROCK A MINIMUM OF 4" BELOW THE PIPE AND 1' ABOVE THE TEE OR WYE, AND LATERAL.
4. IF RISER IS NOT BUILT, PLUG WYE BRANCH WITH STOPPER.
5. INSTALL A SEWER LOCATOR DISK AT THE END OF ALL LATERAL RUNS AT RIGHT OF WAY.
6. ONLY LATERAL RUNS ARE PERMITTED TO BE EITHER "BELL AND SPIGOT", OR "BAND SEAL".
7. WHERE LATERALS ARE INSTALLED IN DRIVEWAYS, A TRAFFIC RATED BOX IS REQUIRED.
8. IF THE LATERAL IS INSTALLED UNDER A PERMANENT HARDSCAPE SUCH AS A CONCRETE DRIVEWAY ALL THE WAY TO THE STRUCTURE, THEN A CUT OFF WALL IS NOT REQUIRED.

**TYPICAL SEWER LATERAL**

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

S-22

Sheet 1 of 1