



**NOTE:**

1. BACKWATER VALVES ARE REQUIRED WHENEVER THE LOWEST FIXTURE IN THE BUILDING (USUALLY THE DOWNSTAIRS SHOWER OR FLOOR DRAIN) IS LOWER IN ELEVATION THAN AN ELEVATION TWELVE (12) INCHES ABOVE THE RIM OF THE NEAREST UPSTREAM SEWER MANHOLE FROM WHERE THE LATERAL TIES INTO.
2. WHERE LATERALS ARE INSTALLED IN DRIVEWAYS, A VEHICULAR TRAFFIC RATED BOX WILL BE REQUIRED OVER ALL CLEANOUTS ON LATERALS.

## BACKWATER VALVE INSTALLATION DETAIL

2016



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on March 16, 2016 as Resolution No. 2016-13

S-25