

OUTSIDE WALL

24" SAMPLE BOX - 24" CAST IRON
FRAME AND COVER PER
YVWD STD.
DWG. S-5

CLEAN OUT PER YVWD
STD. DWG.S-22

SIDEWALK OR DRIVEWAY

VARIES

TO DISTRICT SEWER

LATERAL SIZE PER PLAN

13" MIN.
25" MAX.

FOUNDATION

FLOW

36"

6"

SEWER SAMPLING BOX

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

S-26

Sheet 1 of 1