



NOTES:

1. LOCATION AND DEPTH OF EXISTING AND PROPOSED UTILITIES MUST BE PROVIDED BY THE SUBDIVIDER AND SHOWN ON ANY PLANS SUBMITTED TO Y.V.W.D. FOR APPROVAL.
2. FIRE HYDRANTS SHALL BE PLACED WITHIN THE SIDEWALK 2'-0" TO CENTER LINE OF BARREL BEHIND FACE OF CURB.
3. CHANGES MAY BE PERMITTED BY Y.V.W.D. IN CASES OF CONFLICTING FACILITIES.
4. CONFLICTS BETWEEN UTILITY COMPANIES FACILITIES, EXISTING AND PROPOSED, MUST BE MUTUALLY RESOLVED BY THE UTILITY COMPANIES.
5. BACKFILL UNDER EXISTING CURB WITHIN THE CITY OF YUCAIPA, MUST BE 2 SACK SLURRY PER CITY STANDARDS.

6 PIPING SHOULD BE LOCATED 6'-0" TO ROAD CENTERLINE WHEN POSSIBLE, EXCEPT IN DIVIDED ROADWAYS.

UTILITY LOCATIONS – SECTIONS

2016



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on March 16, 2016 as
Resolution No. 2016-13

W-3