



**NOTES:**

1. LOCATION AND DEPTH OF EXISTING AND PROPOSED UTILITIES MUST BE PROVIDED BY THE SUBDIVIDER AND SHOWN ON ANY PLANS SUBMITTED TO Y.V.W.D. FOR APPROVAL.
2. FIRE HYDRANTS SHALL BE PLACED WITHIN THE SIDEWALK 2'-0" TO CENTER LINE OF BARREL BEHIND FACE OF CURB.
3. CHANGES MAY BE PERMITTED BY Y.V.W.D. IN CASES OF CONFLICTING FACILITIES.
4. CONFLICTS BETWEEN UTILITY COMPANIES FACILITIES, EXISTING AND PROPOSED, MUST BE MUTUALLY RESOLVED BY THE UTILITY COMPANIES.
5. BACKFILL UNDER EXISTING CURB WITHIN THE CITY OF YUCAIPA, MUST BE 2 SACK SLURRY PER CITY STANDARDS.

6 PIPING SHOULD BE LOCATED 6'-0" TO ROAD CENTERLINE WHEN POSSIBLE, EXCEPT IN DIVIDED ROADWAYS.

## UTILITY LOCATIONS – SECTIONS

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

W-3