


SEE SHEET 2 OF 3 FOR ADDITIONAL NOTES, SHEET 3 OF 3 FOR LIST OF MATERIALS

DUAL PLUMBED RESIDENTIAL PROPERTIES REQUIRING 1" FIRE SPRINKLER SERVICE

2016	 Yucaipa Valley Water District	Approved by the Yucaipa Valley Water District Board of Directors on March 16, 2016 as Resolution No. 2016-13	W-4
		Sheet 1 of 3	

NOTES:

1. SERVICE SADDLE SHALL NOT BE INSTALLED WITHIN 12" OF VALVE, COUPLING, JOINT OR FITTING.
2. BLUE POLY-SLEEVE SHALL BE SECURED AT THE CORP. AND THE ANGLE VALVE WITH 10 MIL. TAPE.
3. SET TOP OF METER BOX FLUSH WITH DRIVEWAY, SIDEWALK OR CURB, AS SHOWN.
4. THE CORPORATION STOP TAP SHALL BE MADE AT A 45° DEGREE ANGLE FROM THE TOP OF THE PIPE.
5. THE WATER SERVICE SHALL EXTEND PERPENDICULAR TO THE CENTERLINE OF THE STREET FROM THE WATER MAIN TO THE METER STOP.
6. ALL CONNECTIONS TO COPPER TUBING SHALL BE COMPRESSION FITTINGS.
7. RECYCLED SERVICES WILL BE LOCATED ON THE PROPERTY LINES IN PAIRS. MINIMUM SEPARATION FROM POTABLE TO RECYCLED SERVICES IS (10').
8. METERS AND BACKFLOW BRANCH ASSEMBLY TO BE CENTERED IN METER BOXES TO ALLOW FOR ACCESS, TESTING, AND MAINTENANCE.
9. METER, METER COUPLINGS, BACKFLOW BRANCH ASSEMBLY LOCK ON/LOCK OFF BALL VALVES, AND SINGLE CHECK VALVE ARE TO BE PROVIDED BY THE PURVEYOR.
10. ALL DUAL PLUMBED SERVICES WITH A FIRE SERVICE ARE REQUIRED TO HAVE A DOUBLE CHECK BACKFLOW PREVENTION ASSEMBLY INSTALLED AND TESTED PRIOR TO SERVICES BEING TURNED ON.
11. SUBJECT TO PURVEYOR REVIEW AND APPROVAL, THE METER AND METER BOX INCLUDING THE BRANCH ASSEMBLY MAY BE INSTALLED PARALLEL TO THE CURB IF NECESSARY.



*POTABLE WATER METER SHALL BE LOCATED A MINIMUM OF 10- FEET AWAY FROM THE RECYCLED WATER SERVICE AND SEWER LATERAL, AND 3- FEET AWAY FROM THE E.C./B.C. OF THE DRIVEWAY APPROACH. IF THESE SEPARATIONS ARE NOT POSSIBLE, THE POTABLE WATER METER MAY BE LOCATED WITHIN THE DRIVEWAY BEHIND THE APPROACH BY SPECIAL PERMISSION ONLY.

DUAL PLUMBED RESIDENTIAL PROPERTIES REQUIRING 1" FIRE SPRINKLER SERVICE

2016



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on March 16, 2016 as Resolution No. 2016-13

W-4

Sheet 2 of 3

LIST OF MATERIALS

ITEM NO.	SIZE & DESCRIPTION	MANUFACTURER	SPEC. NO.
1A	DOUBLE STRAP SERVICE SADDLE 1" I.P. OUTLET (FOR D.I.P. MAINS)	JONES ROMAC FORD MUELLER	J-979-PIPE O.D. -1" I.P. 202BS-PIPE O.D. -1" I.P. 202BS-PIPE O.D. -1" I.P. BR2B-PIPE O.D. -I.P. 100
1B	CAST SERVICE SADDLE WITH 1" I.P. OUTLET (FOR D.I.P. MAINS)	ROMAC FORD MUELLER	202S-PIPE O.D.-1" I.P. F-202-PIPE O.D.-1" I.P. DR2A-PIPE O.D.-I.P. 100
2	1" BRONZE BALL CORPORATION STOP (M.I.P.T. X COMPRESSION)	JONES MULLER McDONALD FORD	E-1935SG H-15028N 74704BQ
3	1" BLUE PLASTIC COATED COPPER TUBING		COPPER TYPE "K" SOFT
4	BRONZE BALL ANGLE METER STOP W/LOCKWING (1" COMPRESSION X METER)	JONES MUELLER McDONALD FORD	1963WSG H-14258N 74602BQ
5	1" METER x 3" "METER SPUD"	JONES	J-130
6	1" MINIMUM - DOUBLE CHECK BACKFLOW ASSEMBLY	AMES FEBCO WILKINS ARI	2000SS 850 950XL DC-500
7	1" BRASS UNION		
8	1" "U"-BRANCH (M.I.P.T. X M.I.P.T.)	McDONALD	AYM-708UMM
9	1" DOUBLE CHECK (INLINE DOUBLE CHECK)	McDONALD	711-4FE 44
10	BALL VALVE WITH LOCKWING (F.I.P. X F.I.P.)	JONES MUELLER McDONALD FORD	E-1900W B20283 N AYM76101W
11	METER BOX AND COVER WITH READING LID	ARMOR CAST	A6001430PCX12 W/ (1)-A6001470 - COVER (1)-A6001470DZ - COVER (1)-A6000482

DUAL PLUMBED RESIDENTIAL PROPERTIES REQUIRING 1" FIRE SPRINKLER SERVICE

2016



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on March 16, 2016 as
Resolution No. 2016-13

W-4

Sheet 3 of 3