

1" DRINKING WATER SERVICE WITH FIRE SPRINKLERS

2017



Yucaipa Valley Water District


Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

W-5

Sheet 1 of 3

NOTES:

1. SERVICE SADDLE SHALL NOT BE INSTALLED WITHIN 12" OF VALVE, COUPLING, JOINT OR FITTING.
2. SET TOP OF METER BOX FLUSH WITH DRIVEWAY, SIDEWALK OR CURB, AS SHOWN.
3. THE CORPORATION STOP TAP SHALL BE MADE AT A 45° DEGREE ANGLE FROM THE TOP OF THE PIPE.
4. THE WATER SERVICE SHALL EXTEND PERPENDICULAR TO THE CENTERLINE OF THE STREET FROM THE WATER MAIN TO THE METER STOP.
5. ALL CONNECTIONS TO COPPER TUBING SHALL BE COMPRESSION FITTINGS.
6. METERS AND BRANCH ASSEMBLY TO BE CENTERED IN METER BOXES TO ALLOW FOR ACCESS AND MAINTENANCE
7. WATER METER AND MATERIAL ITEMS 5 TO 8 AND 10 ARE PROVIDED AND SET BY DISTRICT CREWS AT THE DEVELOPERS EXPENSE.
8. SUBJECT TO PURVEYOR REVIEW AND APPROVAL, THE METER AND METER BOX INCLUDING THE BRANCH ASSEMBLY MAY BE INSTALLED PARALLEL TO THE CURB IF NECESSARY.



1" DRINKING WATER SERVICE WITH FIRE SPRINKLERS

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

W-5

Sheet 2 of 3

LIST OF MATERIALS

ITEM NO.	SIZE & DESCRIPTION	MANUFACTURER	SPEC. NO.
1A	DOUBLE STRAP SERVICE SADDLE 1" I.P. OUTLET (FOR D.I.P. MAINS)	JONES ROMAC FORD MUELLER	J-979-PIPE O.D. -1" I.P. 202BS-PIPE O.D. -1" I.P. 202BS-PIPE O.D. -1" I.P. BR2B-PIPE O.D. -I.P. 100
1B	CAST SERVICE SADDLE WITH 1" I.P. OUTLET (FOR D.I.P. MAINS)	ROMAC FORD MUELLER	202S-PIPE O.D.-1" I.P. F-202-PIPE O.D.-1" I.P. DR2A-PIPE O.D.-I.P. 100
2	1" BRONZE BALL CORPORATION STOP (M.I.P.T. X COMPRESSION)	JONES MULLER McDONALD FORD	E-1935SG B-25028N 74704BQ FB1100
3	1" BLUE PLASTIC COATED COPPER TUBING		COPPER TYPE "K" SOFT
4	BRONZE BALL ANGLE METER STOP W/LOCKWING (1" COMPRESSION X METER)	JONES MUELLER McDONALD FORD	1963WSG H-14258N 74602BQ BA43-444W-NL
5	1" METER x 3" "METER SPUD"	JONES	J-130
6	1" "U"-BRANCH (M.I.P.T. X M.I.P.T.)	McDONALD	AYM-708UMM
7	1" INLINE DUAL CHECK - FNPT X FNPT	McDONALD	711-4FE 44
8	BALL VALVE WITH LOCKWING (F.I.P. X F.I.P.)	JONES MUELLER McDONALD FORD	E-1900W B20283 N AYM76101W B11-444W-NL
9	METER BOX AND COVER WITH READING LID	ARMOR CAST	A6001430PCX12 W/ CHANNEL FOR BOLT DOWN (1)-A6001470 (1)-A6001470DZ-H7 (1)-A6000482
10	AMI TRANSCEIVER (INSTALLED BY DISTRICT)	SENSUS	SMARTPOINT M2 - MODEL 520M (DUAL PORT) - PIT SET

1" DRINKING WATER SERVICE WITH FIRE SPRINKLERS

2017



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on October 17, 2017
as Resolution No. 2017-24

W-5

Sheet 3 of 3