



SEE SHEET 2 OF 2 FOR LIST OF MATERIALS.

3/4" AND 1" DRINKING WATER SERVICES ON MANIFOLD ASSEMBLY

2017



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on October 17, 2017
as Resolution No. 2017-24

W-6

Sheet 1 of 2

LIST OF MATERIALS

ITEM NUMBER	DESCRIPTION
1	D.I. TEE, MJ X MJ X FLG, RESTRAINED
2	4" FLG X FLG VALVE
3	MJ X FLG ADAPTOR, RESTRAINED
4	4" D.I.P. RESTRAINED
5	D.I. TEE, MJ X MJ X MJ, RESTRAINED WITH MEGA LUGS (SHORT BODY MAY BE USED)
6	CAST SERVICE SADDLE WITH I.P. OUTLET
7	1" COPPER SERVICE INSTALLATION – SEE YVWD STD. DWG. W-5
8	RESTRAINED MECHANICAL JOINT END CAP WITH MEGA LUG RESTRAINT

NOTE:

1. 4-INCH D.I. MANIFOLD ASSEMBLY USED FOR FOUR TO TEN 3/4-INCH AND 1-INCH SERVICES ONLY. ADDITIONAL SERVICES OR LARGER SERVICE SIZES WILL REQUIRE A LARGER DIAMETER D.I. MANIFOLD ASSEMBLY.
2. BACKFILL UNDER EXISTING CURB WITHIN CITY OF YUCAIPA, MUST BE 2 SACK SLURRY PER CITY STANDARDS.

3/4" AND 1" DRINKING WATER SERVICES ON MANIFOLD ASSEMBLIES

2017



Yucaipa Valley Water District

Approved by the Yucaipa
Valley Water District Board of
Directors on October 17, 2017
as Resolution No. 2017-24

W-6

Sheet 2 of 2