



**SPACER PLATE PLAN**

**NOTES:**

1. PROVIDE VALVE STEM EXTENSION WHEN DEPTH TO OPERATING NUT EXCEEDS 48" (FABRICATE EXTENSION TO FIELD MEASUREMENT – SEE NOTE 2)
2. NO VALVE STEM EXTENSION SHALL BE LESS THAN 2 FEET IN LENGTH UNLESS APPROVED BY DISTRICT ENGINEER.
3. PROVIDE TWO SPACER PLATES. FIRST PLATE IS 6" DOWN FROM TOP OF EXTENSION. SECOND PLATE IS 6" UP FROM BOTTOM OF EXTENSION

**VALVE STEM EXTENSION**

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

W-21