



UNDERGROUND INSTALLATIONS						
PIPE SIZE	A	B	C	D	E	VAULT DIM
3"	24"	18"	4'	5'	6'	4'x6'
4"	24"	18"	4'	5'	6'	4'x6'
6"	24"	18"	4'	5'	8'	4'x8'
8"	24"	18"	4'	5'	12'	4'x12'
12"	36"	18"	6'	5'	12'	6'x12'

## PREFABRICATED VAULT WITH LID AND VENT ASSEMBLY

2017



Yucaipa Valley Water District

Approved by the Yucaipa Valley Water District Board of Directors on October 17, 2017 as Resolution No. 2017-24

W-24

Sheet 1 of 1