



NOTES:

1. CONCRETE ENCASEMENT SHALL BE USED WHEN COVER IS LESS THAN 36".
2. ENCASEMENT TO BE PLACED AGAINST UNDISTURBED NATURAL GROUND OR FILL COMPACTED TO 90% RELATIVE DENSITY.
3. NO.4 AND NO.5 STEEL REINFORCING BARS SHALL BE USED AS SPECIFIED.
4. TYPE OF CONCRETE ENCASEMENT TO BE USED WILL BE SHOWN ON PLANS OR AS SPECIFIED BY DISTRICT REPRESENTATIVE TO MEET UNFORESEEN FIELD CONDITIONS. UNLESS NOTED OTHERWISE, ENCASEMENT SHALL BE 3,250 PSI CONCRETE.
5. WHERE SLOPED TRENCHES ARE USED, WALLS WILL NOT BEGIN TO SLOPE CLOSER THAN 12" FROM THE TOP OF THE PIPE.

WATER PIPELINE PROTECTION DETAIL

2016



Yucaipa Valley Water District

Approved by the Yucaipa
 Valley Water District Board of
 Directors on March 16, 2016 as
 Resolution No. 2016-13

W-32